



**Fair
Trading**

Certificate of Approval Declared Article

Pursuant to Electricity (Consumer Safety) Act 2004

Certificate Number: NSW27538

Issued to:	A & A Nexus Trading Pty Ltd	
Class of Article:	Building Wiring Cable.	
Description of Article:	Electrical Cable [Flat, two core and earth (2x1.0 E1.0 mm sq) electrical cable] Conductor: Class 2, plain annealed stranded copper conductors. Insulation: V-90 PVC compound. Sheath : Extruded PVC (3V-90)	
Trade Name or Mark:	'Ducab'	
Ratings:	Volts: 450/750V Watts:	Amperes: Hertz:
	Other Name Plate Particulars:	
Type Reference Code:	2x1 + E1.0 mm sq	
Examined for Compliance With:	AS/NZS 5000.2 : 2006	
Approval Mark:	Each electrical article of the abovementioned type shall be marked with Approval Number NSW27538 or approved alternate mark	
Date of Approval:	21/07/2016	
Approval Expires:	21/07/2021 <i>unless suspended, cancelled, renewed or extended</i>	



On behalf of the Commissioner for Fair Trading

For current information regarding currency of certificate, refer to the Fair Trading Website

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW27538 Particulars of Modification(s)

The addition of the following cables:-

- (a) Flat, Two-Core and Earth: 2x1.5 + E1.5 mm sq.
Conductor: Class 2, plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x1.5 + E1.5 mm sq.

- (b) Flat, Two-Core and Earth: 2x2.5 + E2.5 mm sq.
Conductor: Class 2, Plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No. 2x2.5 + E2.5 mm sq.

- (c) Flat, Two-Core and Earth: 2x4 + E2.5 mm sq.
Conductor: Class 2, Plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No. 2x4 + E2.5 mm sq.

- (d) Flat, Two-Core and Earth: 2x6 + E2.5 mm sq.
Conductor: Class 2, Plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x6 + E2.5 mm sq

.../2



- (e) Flat, Two-Core and Earth: 2x10 + E4 mm sq.
Conductor: Class 2, Plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x10 + E4 mm sq
- (f) Flat, Two-Core and Earth: 2x16 + E6 mm sq.
Conductor: Class 2, plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No. 2x16+ E6 mm sq.
- (g) Flat, Two-Core: 2 x 1 mm sq.
Conductor: Class 2, plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x1 mm sq
- (h) Flat, Two-Core: 2x1.5 mm sq.
Conductor: Class 2, plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x1.5 mm sq.
- (i) Flat, Two-Core: 2x2.5 mm sq
Conductor: Class 2, Plain annealed stranded copper conductors.
Insulation: V-90 PVC Compound.
Sheath: Extruded PVC (3V-90)
Rated Voltage: 450/750V
Cat No: 2x2.5 mm sq.

.../3



Fair
Trading

Ref: NSW27538/1

- | | | |
|-----|--------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| (j) | Flat, Two-Core:
Conductor:
Insulation:
Sheath:
Rated Voltage:
Cat No: | 2x4 mm sq.
Class 2, Plain annealed stranded copper conductors.
V-90 PVC Compound.
Extruded PVC (3V-90)
450/750V
2x4 mm sq. |
| (k) | Flat, Two-Core:
Conductor:
Insulation:
Sheath:
Rated Voltage:
Cat No: | 2x6 mm sq.
Class 2, Plain annealed stranded copper conductors.
V-90 PVC Compound.
Extruded PVC (3V-90)
450/750V
2x6mm sq. |
| (l) | Flat, Two-Core:
Conductor:
Insulation:
Sheath:
Rated Voltage:
Cat No: | 2x10 mm sq.
Class 2, Plain annealed stranded copper conductors.
V-90 PVC Compound.
Extruded PVC (3V-90)
450/750V
2x10 mm sq. |
| (m) | Flat, Two-Core:
Conductor:
Insulation:
Sheath:
Rated Voltage:
Cat No: | 2x16 mm sq.
Class 2, Plain annealed stranded copper conductors.
V-90 PVC Compound.
Extruded PVC (3V-90)
450/750V
2x16 mm sq. |

This certificate will expire on 21/07/2021

Approved: 21 July 2016


For Commissioner for Fair Trading

Energy & Utilities Unit, NSW Fair Trading,
PO Box 972, Parramatta NSW 2124
02 9895 0722

Email: energyapprovals@services.nsw.gov.au
Website: www.fairtrading.nsw.gov.au